

PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	Tangerine Events Ltd
Address:	1 Hampton Road Hamoton Middlesex TW2 5QE



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	Abracadabra Sound & Light
Address:	314 Nelson Road Whitton Middlesex TW2 7AH
Telephone:	020 8893 3313
Mobile:	07860 465769
Email:	pattesting@abra.co.uk
Cert Number:	1-031101
Order Number:	
File Name:	Download 03 December 2021 16-10
Signature:	

PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date
31C-0976			

APPLIANCE DETAILS AND TEST RESULTS										
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
TANGERINE EVENT - OFFICE										
4641	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4642	IEC EXTENSION	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4643	IEC EXTENSION	24/11/21	P	P	P 0.07	P >99.99	S	S	PASS	
4644	IEC EXTENSION	24/11/21	P	P	P 0.08	P >99.99	S	S	PASS	
4645	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4646	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4647	IEC LEAD	24/11/21	P	P	P 0.06	P >99.99	S	S	PASS	
4648	IEC LEAD	24/11/21	P	P	P 0.04	P 82.67	S	S	PASS	
4649	IEC LEAD	24/11/21	P	P	P 0.04	P 27.17	S	S	PASS	
4650	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4651	IEC LEAD	24/11/21	P	P	P 0.05	P >99.99	S	S	PASS	
4652	IEC LEAD	24/11/21	P	P	P 0.05	P >99.99	S	S	PASS	
4653	IEC LEAD	24/11/21	P	P	P 0.03	P >99.99	S	S	PASS	
4654	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4655	IEC LEAD	24/11/21	P	P	P 0.03	P >99.99	S	S	PASS	
4656	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4657	IEC LEAD	24/11/21	P	P	P 0.06	P >99.99	S	S	PASS	
4658	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	
4659	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
4660	IEC LEAD	24/11/21	P	P	P 0.03	P >99.99	S	S	PASS
4661	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4662	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4663	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4664	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4665	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4666	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4667	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4668	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4669	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4670	HK AKTOR DX	24/11/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4671	IEC LEAD	24/11/21	P	P	P 0.03	P >99.99	S	S	PASS
4672	X32 DESK	24/11/21	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
4673	HK AKTOR	24/11/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4674	HK AKTOR	24/11/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4675	HK AKTOR	24/11/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4676	SMOKE MACHINE	24/11/21	P	S	P 0.07	P >99.99	P 0.69	P <0.10	PASS
4677	ADJ PROFILE	24/11/21	P	S	P 0.06	P >99.99	P 0.09	P 0.11	PASS
4678	ADJ PROFILE	24/11/21	P	S	P 0.07	P >99.99	P 0.06	P 0.11	PASS
4679	MEGA PAR	24/11/21	P	S	S	P >99.99	S	S	PASS
4680	MEGA PAR	24/11/21	P	S	S	P >99.99	S	S	PASS
4681	DOTZ PAR	24/11/21	P	S	P 0.06	P >99.99	P 0.05	P 0.17	PASS
4682	CHAUVET BAR	24/11/21	P	S	P 0.07	P >99.99	P 0.08	P <0.10	PASS
4683	4 BAR	24/11/21	P	S	P 0.07	P 79.01	P <0.05	P <0.10	PASS
4684	KAM LED RODEO	24/11/21	P	S	P 0.08	P 14.72	P 0.06	P 0.21	PASS
4685	ADJ PANEL	24/11/21	P	S	P 0.06	P >99.99	P <0.05	P <0.10	PASS
4686	ADJ PANEL	24/11/21	P	S	P 0.06	P >99.99	P <0.05	P <0.10	PASS
4687	IEC LEAD	24/11/21	P	P	P 0.03	P >99.99	S	S	PASS
4688	HK LINEAR SUB	24/11/21	P	S	P 0.07	P 2.75	P <0.05	P <0.10	PASS
4689	HK LINEAR SUB	24/11/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4690	HK LINEAR SUB	24/11/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4691	HK LINEAR SUB	24/11/21	P	S	P 0.07	P 2.87	P <0.05	P <0.10	PASS
4692	LINEAR 5	24/11/21	P	S	P 0.07	P >99.99	P 0.11	P 0.18	PASS
4693	HK LINEAR 5	24/11/21	P	S	P 0.07	P 58.71	P 0.11	P 0.18	PASS
4694	YAMAHA DSR115	24/11/21	P	S	P 0.07	P >99.99	P 0.16	P 0.31	PASS
4695	YAMAHA DSR115	24/11/21	P	S	P 0.07	P >99.99	P 0.17	P 0.32	PASS
4696	CORE PAR	24/11/21	P	S	P 0.08	P >99.99	P 0.12	P 0.33	PASS
4697	ADJ DOTZ	24/11/21	P	S	P 0.07	P >99.99	P 0.06	P 0.17	PASS
4698	ADJ DOTZ	24/11/21	P	S	P 0.07	P >99.99	P 0.06	P 0.18	PASS
4699	YAMAHA MG102	24/11/21	P	S	S	P >99.99	S	S	PASS
4700	QU16	24/11/21	P	S	P 0.18	P 27.34	P <0.05	P <0.10	PASS
4701	BASS AMP	24/11/21	P	S	P 0.12	P >99.99	P <0.05	P <0.10	PASS
4702	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4703	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4704	IEC LEAD	24/11/21	P	P	P 0.03	P >99.99	S	S	PASS
4705	IEC LEAD	24/11/21	P	P	P 0.06	P >99.99	S	S	PASS
4706	IEC LEAD	24/11/21	P	P	P 0.05	P >99.99	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
4707	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4708	IEC LEAD	24/11/21	P	P	P 0.04	P >99.99	S	S	PASS
4709	IEC LEAD	24/11/21	P	P	P 0.02	P >99.99	S	S	PASS
4710	IEC LEAD	24/11/21	P	P	P 0.02	P >99.99	S	S	PASS

Total Appliances > **70**

Total Appliances For Report: 70