Customer No.:	Tangerine Ev	Inspect. rec. No.:	1349	Order No.:	680

Thames PAT Testing
07905 425 256
City & Guilds Qualified

ELECTRICAL EQUIPMENT TEST REPORT

Full detailed PRO

Room Tangerine Events — **Building**

Appliance/Project
000425
Appliance name/Device
Haze Machine
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.08 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.06 mA	Pass

Appliance/Project
000426
Appliance name/Device
Profile Panel
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.06 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.12 mA	Pass

Appliance/Project
000427
Appliance name/Device
Color Band Lights
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.03 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.36 mA	Pass

Appliance/Project
000428
Appliance name/Device
Colorband Light
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.02 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.37 mA	Pass

Appliance/Project
000429
Appliance name/Device
Allen & Heath QU16
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.03 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.93 mA	Pass

Appliance/Project
000430
Appliance name/Device
LED Spotlight Array
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.13 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass

Signature: Customer: Operator:

Customer No.:	Tangerine Ev	Inspect. rec. No.:	1349	Order No.:	680

Thames PAT Testing
07905 425 256
City & Guilds Qualified

ELECTRICAL EQUIPMENT TEST REPORT

Full detailed PRO

Room Tangerine Events — **Building**

Appliance/Project 000430
Appliance name/Device LED Spotlight Array
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Subleakage	30.0V	2s	230V					5.00 mA	0.03 mA	Pass

Appliance/Project 000431
Appliance name/Device LED Spotlight Array
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.07 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.30 mA	Pass

Appliance/Project 000432
Appliance name/Device Linear 5 Speaker
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.13 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.26 mA	Pass

Appliance/Project 000433
Appliance name/Device Linear 5 Speaker
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.15 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.26 mA	Pass

Appliance/Project 000434
Appliance name/Device Chauvet Par Cans Light
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.04 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.38 mA	Pass

Appliance/Project 000435
Appliance name/Device Linear 5 118 Speaker
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.13 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.34 mA	Pass

Signature: Customer: Operator:

Customer No.:	Tangerine Ev	Inspect. rec. No.:	1349	Order No.:	680

Thames PAT Testing
07905 425 256

City & Guilds Qualified

ELECTRICAL EQUIPMENT TEST REPORT

Full detailed PRO

Room Tangerine Events **Building**

Appliance/Project
000436
Appliance name/Device
Linear 5 118 Speaker
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.05 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.33 mA	Pass

Appliance/Project
000437
Appliance name/Device
Linear 5 118 Speaker
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.09 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.34 mA	Pass

Appliance/Project
000438
Appliance name/Device
Linear 5 118 Speaker
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.04 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.35 mA	Pass

Appliance/Project
000439
Appliance name/Device
Linear 200A Sub
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.03 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	2.05 mA	Pass

Appliance/Project
000440
Appliance name/Device
Linear 5 115 Speaker
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.02 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.80 mA	Pass

Appliance/Project
000441
Appliance name/Device
Linear 5 115 Speaker
Serial
22140206

Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User

Status
Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.03 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass

Signature:	Customer:	Operator:

Customer No.:	Tangerine Ev	Inspect. rec. No.:	1349	Order No.:	680

Thames PAT Testing
07905 425 256
City & Guilds Qualified

ELECTRICAL EQUIPMENT TEST REPORT

Full detailed PRO

Room Tangerine Events **Building**

Appliance/Project 000441
Appliance name/Device Linear 5 115 Speaker
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Subleakage	30.0V	2s	230V					5.00 mA	0.81 mA	Pass

Appliance/Project 000442
Appliance name/Device Linear 200A Sub
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.05 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.03 mA	Pass

Appliance/Project 000443
Appliance name/Device Linear 200A Sub
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.08 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	2.01 mA	Pass

Appliance/Project 000444
Appliance name/Device Linear 200A Sub
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.06 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.03 mA	Pass

Appliance/Project 000445
Appliance name/Device Haze Machine
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Insulation	500V	2s						2 MΩ	R = 17.01 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.04 mA	Pass

Appliance/Project 000446
Appliance name/Device Chauvet Par Cans
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.02 Ω	Pass
Insulation	500V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.39 mA	Pass

Signature: Customer: Operator:

Customer No.:	Tangerine Ev	Inspect. rec. No.:	1349	Order No.:	680

Thames PAT Testing
07905 425 256
City & Guilds Qualified

ELECTRICAL EQUIPMENT TEST REPORT

Full detailed PRO

Room Tangerine Events — **Building**

Appliance/Project 000447
Appliance name/Device Power Supply
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Insulation	500V	2s						2 MΩ	R = >200 MΩ	Pass
									Um = 525 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.01 mA	Pass

Appliance/Project 000448
Appliance name/Device Colorband Light
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.02 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.35 mA	Pass

Appliance/Project 000449
Appliance name/Device Colorband Light
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.02 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.32 mA	Pass

Appliance/Project 000450
Appliance name/Device Spotlight Array
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.04 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.40 mA	Pass

Appliance/Project 000451
Appliance name/Device Spotlight Array
Serial 22140206
Test Date 28. Apr 2025
Retest Date 28. Apr 2026
Comment
Test Site Kings Rd, Teddington
User
Status Pass

Measurement	Parameter 1	Parameter 2	Parameter 3	Parameter 4	Parameter 5	Parameter 6	Parameter 7	Limit	Result	Status
Earth Continuity	200mA	5s						0.20 Ω	0.10 Ω	Pass
Insulation	250V	2s						1 MΩ	R = >200 MΩ	Pass
									Um = 263 V	Pass
Subleakage	30.0V	2s	230V					5.00 mA	0.33 mA	Pass

Signature:	Customer:	Operator: